



Date: 29-04-2026

To,

The Principal

Heritage Xperiential Learning School- sector 62

Gurgaon, Haryana

Respected Ma'am/Sir,

The test reports for the Water samples collected from the campus of Heritage Xperiential Learning School- sector 62 Gurgaon, Haryana are enclosed with this letter. The table below contains the details of the samples collected and the summary of the test results.

S. No.	Item	Place	BCMS Test Slip No.	Sample Collected Date	Result
1	RO Water	SP-1	SYS1040	29-04-2026	Sample Ok
2	RO Water	SP-2	SYS1041	29-04-2026	Sample Ok
3	RO Water	JP	SYS1042	29-04-2026	Sample Ok
4	RO Water	Canteen	SYS1043	29-04-2026	Sample Ok
5	RO Water	MP	SYS1044	29-04-2026	Sample Ok
6	RAW Water	Borwell	SYS1045	29-04-2026	Sample Ok

Thanking You

Authorized Signatory

Blue Circle Medi Services Pvt. Ltd.

Encl. : 1-The Scan Copy of test reports from the test lab.

**Blue Circle Medi Services Pvt. Ltd.**

J-32, Sarita Vihar , New Delhi – 110076, Ph : 011-41403319, E-mail : [info@bluecircle.in](mailto:info@bluecircle.in)



TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502194

REPORT ISSUE DATE: 08/05/2026

CLIENT/ISSUED TO	YOUR REF:	TRF
Blue Circle Medi Services Pvt Ltd	DATED:	29.04.2026
J-33, Sarita Vihar, New Delhi-76	ULR NO:	TC516026000016926F
	-	-

DETAILS PROVIDED BY CUSTOMER:	
NAME OF THE PRODUCT	RO Water
SAMPLE DETAILS	Sample Point: SP-1 Sampling Location: Heritage School Ullahawas, Sec-62, Gurgaon (HR) 122098
TEST REQUIRED	Chemical & Biological Test
ANY OTHER INFORMATION	Sample Drawn by Intertek representative Narender Sampling date: 29/03/2026, 03:00PM to 04:00PM

LAB INFORMATION:			
SAMPLE REGISTRATION NUMBER	IFSH-260502194		
SAMPLE REGISTRATION DATE	02/05/2026		
ANALYSIS STARTING DATE	02/05/2026	ANALYSIS COMPLETION DATE	08/05/2026
SAMPLE QUANTITY RECEIVED	3 ltr in plastic bottle	SAMPLE CONDITION	Intact
SAMPLE RECEIPT DATE	02/05/2026	REPORTING CODE	FS/CR/KS
SAMPLE TESTED AS RECEIVED			





TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502194

REPORT ISSUE DATE: 08/05/2026

Product Group: Water  
Discipline: Chemical Testing  
ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Specification IS:10500-2012		Limit of Quantification	Method of Testing
				Acceptable Limit	Permissible Limit (In the absence of alternate source)		
<b>Chemical Parameters</b>							
1.	Colour	Hazen	<1.0	Max 5	Max 15	1	IS 3025 P-4: 2021
2.	Odour	-	Agreeable	Agreeable	Agreeable	-	IS:3025 (P-5): 2018
3.	Taste	-	Agreeable	Agreeable	Agreeable	-	IS:3025 (P-8): 2023
4.	Turbidity	NTU	<1.0	Max 1.0	Max 5.0	1.0	IS:3025 (P-10) Sec-2: 2024
5.	Total Dissolved solids	mg/l	30.1	Max 500	Max 2000	10.0	IS:3025 (P-16): 2023
6.	pH	-	6.54	6.5- 8.5	No Relaxation	2.0	IS:3025 (P-11): 2022
7.	Total Hardness (as CaCO <sub>3</sub> )	mg/l	12.5	Max 200	Max 600	5.0	IS:3025 (P- 21): 2009
8.	Nitrate	mg/l	1.15	Max 45.0	No relaxation	1.0	IS 3025 (P-34) Sec 1:2023
9.	Chloride (as Cl)	mg/l	6.1	Max 250	Max 1000	5.0	IS:3025 (P-32): Sec-2:2021





TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502194

REPORT ISSUE DATE: 08/05/2026

Product Group: Water

Discipline: Biological Testing

ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Requirements IS: 10500:2012	Limit of Quantification	Method of Testing
	Biological Parameters					
1.	<i>Escherichia coli</i>	/100ml	Absent	Absent	Absent	IS: 15185: 2016
2.	Coliform	/100ml	Absent	Absent	Absent	IS: 15185: 2016
3.	Standard plate count*	cfu/ml	32	-	≥1.0	SMWW 24 <sup>th</sup> Ed - 9215 B (APHA)

\* Not in specification of IS: 10500:2012

**Note-01:** The above results relate only to the sample tested.

**Note-02:** The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.

**Remarks1:** - The submitted sample complies to 'IS 10500:2012 requirements' wherever mentioned with respect to the above parameters only.

\*\*\*\*\*END OF TEST REPORT\*\*\*\*\*

Authorized Signatory

**G. Sonia Kumari**  
Assistant Manager -Microbiology

Authorized Signatory

**CH. Shravan Kumar**  
Technical Manager





TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502195

REPORT ISSUE DATE: 08/05/2026

CLIENT/ISSUED TO	YOUR REF:	TRF
Blue Circle Medi Services Pvt Ltd	DATED:	29.04.2026
J-33, Sarita Vihar, New Delhi-76	ULR NO:	TC516026000016927F
	-	-

DETAILS PROVIDED BY CUSTOMER:	
NAME OF THE PRODUCT	RO Water
SAMPLE DETAILS	Sample Point: SP-2 Sampling Location: Heritage School Ullahawas, Sec-62, Gurgaon (HR) 122098
TEST REQUIRED	Chemical & Biological Test
ANY OTHER INFORMATION	Sample Drawn by Intertek representative Narender Sampling date: 29/03/2026, 03:00PM to 04:00PM

LAB INFORMATION:			
SAMPLE REGISTRATION NUMBER	IFSH-260502195		
SAMPLE REGISTRATION DATE	02/05/2026		
ANALYSIS STARTING DATE	02/05/2026	ANALYSIS COMPLETION DATE	08/05/2026
SAMPLE QUANTITY RECEIVED	3 ltr in plastic bottle	SAMPLE CONDITION	Intact
SAMPLE RECEIPT DATE	02/05/2026	REPORTING CODE	FS/CR/KS
SAMPLE TESTED AS RECEIVED			





TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502195

REPORT ISSUE DATE: 08/05/2026

Product Group: Water  
Discipline: Chemical Testing  
ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Specification IS:10500-2012		Limit of Quantification	Method of Testing
				Acceptable Limit	Permissible Limit (In the absence of alternate source)		
<b>Chemical Parameters</b>							
1.	Colour	Hazen	<1.0	Max 5	Max 15	1	IS 3025 P-4: 2021
2.	Odour	-	Agreeable	Agreeable	Agreeable	-	IS:3025 (P-5): 2018
3.	Taste	-	Agreeable	Agreeable	Agreeable	-	IS:3025 (P-8): 2023
4.	Turbidity	NTU	<1.0	Max 1.0	Max 5.0	1.0	IS:3025 (P-10) Sec-2: 2024
5.	Total Dissolved solids	mg/l	69.5	Max 500	Max 2000	10.0	IS:3025 (P-16): 2023
6.	pH	-	6.74	6.5- 8.5	No Relaxation	2.0	IS:3025 (P-11): 2022
7.	Total Hardness (as CaCO <sub>3</sub> )	mg/l	31.2	Max 200	Max 600	5.0	IS:3025 (P-21): 2009
8.	Nitrate	mg/l	5.17	Max 45.0	No relaxation	1.0	IS 3025 (P-34) Sec 1:2023
9.	Chloride (as Cl)	mg/l	18.4	Max 250	Max 1000	5.0	IS:3025 (P-32): Sec-2:2021





TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502195

REPORT ISSUE DATE: 08/05/2026

Product Group: Water

Discipline: Biological Testing

ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Requirements IS: 10500:2012	Limit of Quantification	Method of Testing
	Biological Parameters					
1.	<i>Escherichia coli</i>	/100ml	Absent	Absent	Absent	IS: 15185: 2016
2.	Coliform	/100ml	Absent	Absent	Absent	IS: 15185: 2016
3.	Standard plate count*	cfu/ml	28	-	≥1.0	SMWW 24 <sup>th</sup> Ed - 9215 B (APHA)

\* Not in specification of IS: 10500:2012

**Note-01:** The above results relate only to the sample tested.

**Note-02:** The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.

**Remarks1:** - The submitted sample complies to 'IS 10500:2012 requirements' wherever mentioned with respect to the above parameters only.

\*\*\*\*\*END OF TEST REPORT\*\*\*\*\*

Authorized Signatory

**G. Sonia Kumari**  
Assistant Manager -Microbiology

Authorized Signatory

**CH. Shravan Kumar**  
Technical Manager





TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502196

REPORT ISSUE DATE: 08/05/2026

CLIENT/ISSUED TO	YOUR REF:	TRF
Blue Circle Medi Services Pvt Ltd	DATED:	29.04.2026
J-33, Sarita Vihar, New Delhi-76	ULR NO:	TC516026000016928F
	-	-

DETAILS PROVIDED BY CUSTOMER:	
NAME OF THE PRODUCT	RO Water
SAMPLE DETAILS	Sample Point: JP Sampling Location: Heritage School Ullahawas, Sec-62, Gurgaon (HR) 122098
TEST REQUIRED	Chemical & Biological Test
ANY OTHER INFORMATION	Sample Drawn by Intertek representative Narender Sampling date: 29/03/2026, 03:00PM to 04:00PM

LAB INFORMATION:			
SAMPLE REGISTRATION NUMBER	IFSH-260502196		
SAMPLE REGISTRATION DATE	02/05/2026		
ANALYSIS STARTING DATE	02/05/2026	ANALYSIS COMPLETION DATE	08/05/2026
SAMPLE QUANTITY RECEIVED	3 ltr in plastic bottle	SAMPLE CONDITION	Intact
SAMPLE RECEIPT DATE	02/05/2026	REPORTING CODE	FS/CR/KS
SAMPLE TESTED AS RECEIVED			





TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502196

REPORT ISSUE DATE: 08/05/2026

Product Group: Water  
Discipline: Chemical Testing  
ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Specification IS:10500-2012		Limit of Quantification	Method of Testing
				Acceptable Limit	Permissible Limit (In the absence of alternate source)		
<b>Chemical Parameters</b>							
1.	Colour	Hazen	<1.0	Max 5	Max 15	1	IS 3025 P-4: 2021
2.	Odour	-	Agreeable	Agreeable	Agreeable	-	IS:3025 (P-5): 2018
3.	Taste	-	Agreeable	Agreeable	Agreeable	-	IS:3025 (P-8): 2023
4.	Turbidity	NTU	<1.0	Max 1.0	Max 5.0	1.0	IS:3025 (P-10) Sec-2: 2024
5.	Total Dissolved solids	mg/l	21.0	Max 500	Max 2000	10.0	IS:3025 (P-16): 2023
6.	pH	-	6.53	6.5- 8.5	No Relaxation	2.0	IS:3025 (P-11): 2022
7.	Total Hardness (as CaCO <sub>3</sub> )	mg/l	8.3	Max 200	Max 600	5.0	IS:3025 (P- 21): 2009
8.	Nitrate	mg/l	BLQ	Max 45.0	No relaxation	1.0	IS 3025 (P-34) Sec 1:2023
9.	Chloride (as Cl)	mg/l	5.1	Max 250	Max 1000	5.0	IS:3025 (P-32): Sec-2:2021





TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502196

REPORT ISSUE DATE: 08/05/2026

Product Group: Water

Discipline: Biological Testing

ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Requirements IS: 10500:2012	Limit of Quantification	Method of Testing
	Biological Parameters					
1.	Escherichia coli	/100ml	Absent	Absent	Absent	IS: 15185: 2016
2.	Coliform	/100ml	Absent	Absent	Absent	IS: 15185: 2016
3.	Standard plate count*	cfu/ml	27	-	≥1.0	SMWW 24 <sup>th</sup> Ed - 9215 B (APHA)

Below Limit of Quantification(BLQ)

\* Not in specification of IS: 10500:2012

Note-01: The above results relate only to the sample tested.

Note-02: The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.

Remarks1: - The submitted sample complies to 'IS 10500:2012 requirements' wherever mentioned with respect to the above parameters only.

\*\*\*\*\*END OF TEST REPORT\*\*\*\*\*

Authorized Signatory

G. Sonia Kumari  
Assistant Manager -Microbiology

Authorized Signatory

CH. Shrvan Kumar  
Technical Manager





TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502197

REPORT ISSUE DATE: 08/05/2026

CLIENT/ISSUED TO	YOUR REF:	TRF
Blue Circle Medi Services Pvt Ltd	DATED:	29.04.2026
J-33, Sarita Vihar, New Delhi-76	ULR NO:	TC516026000016929F
	-	-

DETAILS PROVIDED BY CUSTOMER:	
NAME OF THE PRODUCT	RO Water
SAMPLE DETAILS	Sample Point: Canteen Sampling Location: Heritage School Ullahawas, Sec-62, Gurgaon (HR) 122098
TEST REQUIRED	Chemical & Biological Test
ANY OTHER INFORMATION	Sample Drawn by Intertek representative Narender Sampling date: 29/03/2026, 03:00PM to 04:00PM

LAB INFORMATION:			
SAMPLE REGISTRATION NUMBER	IFSH-260502197		
SAMPLE REGISTRATION DATE	02/05/2026		
ANALYSIS STARTING DATE	02/05/2026	ANALYSIS COMPLETION DATE	08/05/2026
SAMPLE QUANTITY RECEIVED	3 ltr in plastic bottle	SAMPLE CONDITION	Intact
SAMPLE RECEIPT DATE	02/05/2026	REPORTING CODE	FS/CR/KS
SAMPLE TESTED AS RECEIVED			





TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502197

REPORT ISSUE DATE: 08/05/2026

Product Group: Water  
Discipline: Chemical Testing  
ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Specification IS:10500-2012		Limit of Quantification	Method of Testing
				Acceptable Limit	Permissible Limit (In the absence of alternate source)		
<b>Chemical Parameters</b>							
1.	Colour	Hazen	<1.0	Max 5	Max 15	1	IS 3025 P-4: 2021
2.	Odour	-	Agreeable	Agreeable	Agreeable	-	IS:3025 (P-5): 2018
3.	Taste	-	Agreeable	Agreeable	Agreeable	-	IS:3025 (P-8): 2023
4.	Turbidity	NTU	<1.0	Max 1.0	Max 5.0	1.0	IS:3025 (P-10) Sec-2: 2024
5.	Total Dissolved solids	mg/l	59.1	Max 500	Max 2000	10.0	IS:3025 (P-16): 2023
6.	pH	-	6.65	6.5- 8.5	No Relaxation	2.0	IS:3025 (P-11): 2022
7.	Total Hardness (as CaCO <sub>3</sub> )	mg/l	22.9	Max 200	Max 600	5.0	IS:3025 (P-21): 2009
8.	Nitrate	mg/l	1.82	Max 45.0	No relaxation	1.0	IS 3025 (P-34) Sec 1:2023
9.	Chloride (as Cl)	mg/l	9.2	Max 250	Max 1000	5.0	IS:3025 (P-32): Sec-2:2021





TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502197

REPORT ISSUE DATE: 08/05/2026

Product Group: Water

Discipline: Biological Testing

ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Requirements IS: 10500:2012	Limit of Quantification	Method of Testing
	Biological Parameters					
1.	Escherichia coli	/100ml	Absent	Absent	Absent	IS: 15185: 2016
2.	Coliform	/100ml	Absent	Absent	Absent	IS: 15185: 2016
3.	Standard plate count*	cfu/ml	30	-	≥1.0	SMWW 24 <sup>th</sup> Ed - 9215 B (APHA)

\* Not in specification of IS: 10500:2012

Note-01: The above results relate only to the sample tested.

Note-02: The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.

Remarks1: - The submitted sample complies to 'IS 10500:2012 requirements' wherever mentioned with respect to the above parameters only.

\*\*\*\*\*END OF TEST REPORT\*\*\*\*\*

Authorized Signatory

G. Sonia Kumari  
Assistant Manager - Microbiology

Authorized Signatory

CH. Shravan Kumar  
Technical Manager





TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502198

REPORT ISSUE DATE: 08/05/2026

CLIENT/ISSUED TO	YOUR REF:	TRF
Blue Circle Medi Services Pvt Ltd	DATED:	29.04.2026
J-33, Sarita Vihar, New Delhi-76	ULR NO:	TC516026000016930F
	-	-

DETAILS PROVIDED BY CUSTOMER:	
NAME OF THE PRODUCT	RO Water
SAMPLE DETAILS	Sample Point: MP Sampling Location: Heritage School Ullahawas, Sec-62, Gurgaon (HR) 122098
TEST REQUIRED	Chemical & Biological Test
ANY OTHER INFORMATION	Sample Drawn by Intertek representative Narender Sampling date: 29/03/2026, 03:00PM to 04:00PM

LAB INFORMATION:			
SAMPLE REGISTRATION NUMBER	IFSH-260502198		
SAMPLE REGISTRATION DATE	02/05/2026		
ANALYSIS STARTING DATE	02/05/2026	ANALYSIS COMPLETION DATE	08/05/2026
SAMPLE QUANTITY RECEIVED	3 ltr in plastic bottle	SAMPLE CONDITION	Intact
SAMPLE RECEIPT DATE	02/05/2026	REPORTING CODE	FS/CR/KS
SAMPLE TESTED AS RECEIVED			





TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502198

REPORT ISSUE DATE: 08/05/2026

Product Group: Water  
Discipline: Chemical Testing  
ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Specification IS:10500-2012		Limit of Quantification	Method of Testing
				Acceptable Limit	Permissible Limit (In the absence of alternate source)		
<b>Chemical Parameters</b>							
1.	Colour	Hazen	<1.0	Max 5	Max 15	1	IS 3025 P-4: 2021
2.	Odour	-	Agreeable	Agreeable	Agreeable	-	IS:3025 (P-5): 2018
3.	Taste	-	Agreeable	Agreeable	Agreeable	-	IS:3025 (P-8): 2023
4.	Turbidity	NTU	<1.0	Max 1.0	Max 5.0	1.0	IS:3025 (P-10) Sec-2: 2024
5.	Total Dissolved solids	mg/l	30.1	Max 500	Max 2000	10.0	IS:3025 (P-16): 2023
6.	pH	-	6.68	6.5- 8.5	No Relaxation	2.0	IS:3025 (P-11): 2022
7.	Total Hardness (as CaCO <sub>3</sub> )	mg/l	12.5	Max 200	Max 600	5.0	IS:3025 (P-21): 2009
8.	Nitrate	mg/l	1.47	Max 45.0	No relaxation	1.0	IS 3025 (P-34) Sec 1:2023
9.	Chloride (as Cl)	mg/l	6.1	Max 250	Max 1000	5.0	IS:3025 (P-32): Sec-2:2021





TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502198

REPORT ISSUE DATE: 08/05/2026

Product Group: Water

Discipline: Biological Testing

ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Requirements IS: 10500:2012	Limit of Quantification	Method of Testing
	<b>Biological Parameters</b>					
1.	Escherichia coli	/100ml	Absent	Absent	Absent	IS: 15185: 2016
2.	Coliform	/100ml	Absent	Absent	Absent	IS: 15185: 2016
3.	Standard plate count*	cfu/ml	26	-	≥1.0	SMWW 24 <sup>th</sup> Ed - 9215 B (APHA)

\* Not in specification of IS: 10500:2012

**Note-01:** The above results relate only to the sample tested.

**Note-02:** The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.

**Remarks1:** - The submitted sample complies to 'IS 10500:2012 requirements' wherever mentioned with respect to the above parameters only.

\*\*\*\*\*END OF TEST REPORT\*\*\*\*\*

Authorized Signatory

**G. Sonia Kumari**  
Assistant Manager -Microbiology

Authorized Signatory

**CH. Shravan Kumar**  
Technical Manager





TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502199

REPORT ISSUE DATE: 08/05/2026

CLIENT/ISSUED TO	YOUR REF:	TRF
Blue Circle Medi Services Pvt Ltd	DATED:	29.04.2026
J-33, Sarita Vihar, New Delhi-76	ULR NO:	TC516026000016931F
	-	-

DETAILS PROVIDED BY CUSTOMER:	
NAME OF THE PRODUCT	Raw Water
SAMPLE DETAILS	Sample Point: Borwell Sampling Location: Heritage School Ullahawas, Sec-62, Gurgaon (HR) 122098
TEST REQUIRED	Chemical & Biological Test
ANY OTHER INFORMATION	Sample Drawn by Intertek representative Narender Sampling date: 29/03/2026, 03:00PM to 04:00PM

LAB INFORMATION:			
SAMPLE REGISTRATION NUMBER	IFSH-260502199		
SAMPLE REGISTRATION DATE	02/05/2026		
ANALYSIS STARTING DATE	02/05/2026	ANALYSIS COMPLETION DATE	08/05/2026
SAMPLE QUANTITY RECEIVED	3 ltr in plastic bottle	SAMPLE CONDITION	Intact
SAMPLE RECEIPT DATE	02/05/2026	REPORTING CODE	FS/CR/KS
SAMPLE TESTED AS RECEIVED			





TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502199

REPORT ISSUE DATE: 08/05/2026

Product Group: Water  
Discipline: Chemical Testing  
ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Specification IS:10500-2012		Limit of Quantification	Method of Testing
				Acceptable Limit	Permissible Limit (In the absence of alternate source)		
<b>Chemical Parameters</b>							
1.	Colour	Hazen	<1.0	Max 5	Max 15	1	IS 3025 P-4: 2021
2.	Odour	-	Agreeable	Agreeable	Agreeable	-	IS:3025 (P-5): 2018
3.	Taste	-	Agreeable	Agreeable	Agreeable	-	IS:3025 (P-8): 2023
4.	Turbidity	NTU	<1.0	Max 1.0	Max 5.0	1.0	IS:3025 (P-10) Sec-2: 2024
5.	Total Dissolved solids	mg/l	746.0	Max 500	Max 2000	10.0	IS:3025 (P-16): 2023
6.	pH	-	7.72	6.5- 8.5	No Relaxation	2.0	IS:3025 (P-11): 2022
7.	Total Hardness (as CaCO <sub>3</sub> )	mg/l	382.7	Max 200	Max 600	5.0	IS:3025 (P-21): 2009
8.	Nitrate	mg/l	10.6	Max 45.0	No relaxation	1.0	IS 3025 (P-34) Sec 1:2023
9.	Chloride (as Cl)	mg/l	171.5	Max 250	Max 1000	5.0	IS:3025 (P-32): Sec-2:2021





TC- 5160

TEST REPORT

ANALYSIS REPORT NO. IFSH-260502199

REPORT ISSUE DATE: 08/05/2026

Product Group: Water  
Discipline: Biological Testing  
ANALYTICAL RESULTS

Sr. No	Test Parameter	Unit of Measurement	Result	Requirements IS: 10500:2012	Limit of Quantification	Method of Testing
	Biological Parameters					
1.	Escherichia coli	/100ml	Absent	Absent	Absent	IS: 15185: 2016
2.	Coliform	/100ml	Absent	Absent	Absent	IS: 15185: 2016
3.	Standard plate count*	cfu/ml	58	-	≥1.0	SMWW 24 <sup>th</sup> Ed - 9215 B (APHA)

\* Not in specification of IS: 10500:2012

**Note-01:** The above results relate only to the sample tested.

**Note-02:** The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.

**Remarks1:** - The submitted sample complies to 'IS 10500:2012 requirements' wherever mentioned with respect to the above parameters only.

\*\*\*\*\*END OF TEST REPORT\*\*\*\*\*

Authorized Signatory

G. Sonia Kumari  
Assistant Manager - Microbiology

Authorized Signatory

CH. Shrvan Kumar  
Technical Manager

